



NOTE: PH3 SURVEY WAS PERFORMED ON 4/30/2010.
NO PH3 DETECTED IN ANY LCDRS MANHOLES.
PH3 DETECTED AT POND 15S CAP DRAINAGE
LIFT STATIONS LS-1 AND LS-2 ONLY.

LEGEND:
LS LIFT STATION
LCDRS LEACHATE COLLECTION, DETECTION AND
REMOVAL SYSTEM

AREA MAP
LIFT STATION & LCDRS LOCATIONS
AT RCRA PONDS